

CALIFORNIA AMERICAN WATER COMPANY

1033 B Avenue, Suite 200

CORONADO, CA 92118

Revised

C.P.U.C. SHEET NO.

8055-W

CANCELLING

Revised

C.P.U.C. SHEET NO.

4087-W

METER TEST RESULTS – METER ACCURATE

California American Water Company

P.O. Box 578, Alton IL 62002

(T,D)

12/01/2015

(T)

Customer Name

Account Number

Customer Mailing Address 1

Premise Number

Customer Mailing Address 2

Service Address

(T)

Dear Customer:

On Monday, November 23, 2015, your water meter was tested at both an intermediate and a full flow of water.

(T)

The testing indicated that your meter was registering 100.0 percent at the full flow and 100.0 percent at the intermediate flow. According to regulations set by the California Public Utilities Commission, a meter is considered operating in a satisfactory manner if it records water use between 98.5 percent and 101.5 percent of actual usage. Therefore, this meter's registration is considered accurate.

If you have any concerns regarding this test, please call us 1-888-237-1333 during California American Water's business hours. Thank you.

(C)

(C)

Sincerely,

(TO BE INSERTED BY UTILITY)

ADVICE LETTER NO. 1092

ISSUED BY

D. P. STEPHENSON

(TO BE INSERTED BY C.P.U.C.)

DATE FILED 11-5-2015

NAME

EFFECTIVE 12-7-2015

DECISION NO. _____

DIRECTOR – Rates & Regulatory

TITLE

RESOLUTION _____