



**NOTES:**

1. CENTER METER IN BOX, MIN 6" CLEARANCE ON ALL SIDES.
2. TRENCH, INSTALL, AND BACKFILL SERVICE LINE IN ACCORDANCE WITH AW SPECIFICATIONS.
3. POINT OF DEMARCATION FOR SERVICE LINE OWNERSHIP PER PRIME CONTRACT BETWEEN AW AND GOVERNMENT.
4. SERVICE LINE MATERIALS SHALL MEET AW SPECIFICATIONS.
5. PROVIDE TRACE WIRE ALONG WATER SERVICE LINE. TRACE WIRE SHALL EXTEND INTO THE CURB BOX AND METER PIT AND TERMINATE IN THE METER PIT.
6. IF WATER SERVICE BETWEEN MAIN AND WATER METER IS REPLACED WITH NON-METALLIC PIPING, THERE SHALL BE A MINIMUM LENGTH OF TEN (10) FT OF METALLIC PIPING BETWEEN THE BUILDING STRUCTURE AND METER PIT TO MAINTAIN PROPER GROUNDING OF BUILDING'S ELECTRICAL SYSTEM.
7. THE CORPORATION STOP SHALL BE INSTALLED BETWEEN 45 DEGREES AND 90 DEGREES TO THE WATER MAIN.

## 2" WATER SERVICE INSTALLATION

REVISIONS
1/16 - MSG EDITS
12/22 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP  
 CIVIL  
 2" WATER SERVICE  
 INSTALLATION DETAIL

AMERICAN WATER MILITARY SERVICES GROUP  
 CAMDEN, NJ 08102

AMERICAN WATER M.S.G.  
 1 WATER STREET  
 CAMDEN, NJ 08102



DRAWN BY Z. ALAM  
 PROJECT ENG'R PDK  
 APPROVED

DATE 05-03-2010  
 PROJECT N/A

USE DIMENSIONS ONLY  
 SCALE N.T.S.

USE APPROVED DRAWINGS ONLY  
 FOR CONSTRUCTION PURPOSES

MSG-W-01

FINAL

MSG-W-01