-- WATER COMPANY DISTRIBUTION MAIN CURB LINE . 4. .1 CURB BOX-CORPORATION STOP METER TILE TO BE SET ON A FLAT BRICK, STONE, OR UNDISTURBED SOIL 22 1/2 NEW JERSEY AMERICAN WATER COMPANY - FIELD SERVICE DEPARTMENT TYPICAL SERVICE LINE INSTALLATION DISTANCE VARIES ACCORDING TO RIGHT OF WAY COPPER METER SHUT OFF VALVE METER BOX — SETTER -REFERENCE CURB STOP METER WITH -TOUCH READ OR RF UNIT WATER COMPANY SERVICE CONNECTION KKKKKKKKKKKKKKKKKKKKKKKKKKKK W/LID & LID BOLT W/TOUCH PAD 18" CUSTOMER OWNED SERVICE LINE 8 MINIMUM COVER 48" - FLOOR VALVE (BY CUSTOMER) BASEMENT FLOOR INSIDE BUILDING WALL MAIN SHUT OFF VALVE (BY CUSTOMER) JOIST -